


SENSOR APPROVAL SHEET

CUSTOMER
PO#
SO#
SHIP DATE
QUANTITY
WIRE LENGTH (ft.)

OPTIONS

- Wire length (min. 50 ft. - 350 ft. max.)
Over 350 call Factory
- Audible Alarm



Waterline Controls
P.O. Box 12544
Scottsdale, Arizona 85260
Toll Free: 888-905-1892
info@waterlinecontrols.com
www.waterlinecontrols.com

SENSOR		STANDARD LENGTHS	
Red	OFF (Fill)	A	15 1/2"
White	ON (Fill)	B	17"
Brown	LOW (Alarm)	C	17"
Black	same length as longest rod		

Name:

Company:

Signature:


Date:

SENSOR APPROVAL SHEET

CUSTOMER
PO#
SO#
SHIP DATE
QUANTITY
WIRE LENGTH (ft.)

OPTIONS

- Wire length (min. 50 ft. - 350 ft. max.)
Over 350 call Factory
- Audible Alarm



Dimensions should be calculated from the top of the tank or riser down to the required alarm level(s) in inches. Be sure to take into account any riser pipes or manway risers.

Waterline Controls
P.O. Box 12544
Scottsdale, Arizona 85260
Toll Free: 888-905-1892
info@waterlinecontrols.com
www.waterlinecontrols.com

SENSOR		LENGTHS	
Red	OFF (Fill)	A	
White	ON (Fill)	B	
Brown	LOW (Alarm)	C	
Black	same length as longest rod		

Name:

Company:

Signature:

Date: